

White City WTP										
August 2022	Raw Volume (m3) Avg	Treated Volume (m3) Avg	Treated Free Chlorine (mg/L) Min	Treated Total Chlorine (mg/L) Min	Treated Free Chlorine (Analyser) (mg/L) Min	Treated pH (Analyser) (pH units) Avg	Treated Turbidity (NTU) Max	Treated Turbidity (Analyser) (NTU) Max	Treated Iron (mg/L) Avg	Treated Manganese (mg/L) Avg
Aug 01	1247	1107	0.91	1.21	0.97	7.10	0.25	0.027	0.01	0.021
02	908	937	0.90	1.21	0.97	7.09	0.25	0.026		0.011
03	1466	1414	0.93	1.24	0.98	7.15	0.31	0.025		0.006
04	1487	1379	0.98	1.32	1.05	7.15	0.26	0.026		0.018
05	1488	1603	0.98	1.33	1.11	7.15	0.24	0.025		0.008
06	1695	1302	1.09	1.45	1.18	7.15	0.23	0.026		0.023
07	1730	1662	1.09	1.45	1.07	7.15	0.23	0.026		0.026
08	1772	1884	1.08	1.45	1.06	7.16	0.20	0.027	0.01	0.028
09	2129	1926	0.99	1.50	1.09	7.15	0.24	0.025	0.01	0.017
10	2166	2094	1.11	1.49	1.10	7.16	0.23	0.029	0.00	0.024
11	1959	1776	1.03	1.39	1.09	7.15	0.27	0.026	0.04	0.017
12	1445	1312	1.05	1.33	1.05	7.15	0.27	0.027		0.026
13	1478	1403	1.05	1.43	0.96	7.10	0.23	0.027		0.014
14	1690	1628	1.02	1.40	0.96	7.14	0.21	0.027		0.014
15	2148	2054	0.96	1.34	0.93	7.07	0.26	0.024	0.00	0.013
16	1264	1136	1.04	1.32	0.93	7.12	0.24	0.026	0.00	0.018
17	1412	1305	1.00	1.31	0.92	7.15	0.28	0.026	0.01	0.031
18	1166	1092	0.94	1.26	0.90	7.15	0.31	0.026		0.019
19	1481	1509	0.95	1.30	0.93	7.15	0.32	0.027		0.007
20	1532	1450	1.03	1.41	0.99	7.14	0.26	0.039		0.024
21	1311	1283	1.01	1.49	1.02	7.14	0.25	0.040		0.020
22	2153	2049	1.12	1.42	1.08	7.12	0.29	0.050	0.00	0.008
23	1610	1506	1.12	1.50	1.07	7.10	0.26	0.046		0.028
24	1784	1664	1.10	1.43	1.08	7.14	0.29	0.052		0.010
25	1630	1471	1.03	1.42	1.04	7.14	0.27	0.052		0.019
26	1388	1486	1.04	1.44	1.05	7.14	0.23	0.057		0.016
27	1650	1440	1.00	1.42	1.02	7.14	0.30	0.060		0.006
28	1297	1089	1.01	1.41	1.00	7.15	0.33	0.060		0.012
29	1012	1044	1.02	1.41	0.98	7.15	0.30	0.058	0.02	0.018
30	999	934	1.00	1.41	0.96	7.15	0.27	0.057		0.023
31	1668	1523	0.96	1.35	1.00	7.13	0.29	0.058	0.01	0.011
Minimum	908	934	0.90	1.21	0.90	7.07	0.20	0.024	0.00	0.006
Maximum	2166	2094	1.12	1.50	1.18	7.16	0.33	0.060	0.04	0.031
Average	1554	1467	1.02	1.38	1.02	7.14	0.26	0.036	0.01	0.017
Count			31	31	31	31	31	31	11	31
Total	48165	45462								
95th Percentile							0.31	0.058		
Exceedences			0		0					

If there is more than one per day reading for free chlorine residual, the daily minimum is reported.

If there is more than one per day reading for turbidity, the daily maximum is reported.

White City WTP - Bacteriological						
August 2022	Total Coliform (Count)	E. Coli (Count)	Background Bacteria (Count)	Free Chlorine (mg/L)	Total Chlorine (mg/L)	Turbidity (NTU)
Aug 02	0	0	0	0.90	1.21	0.25
	0	0	0			0.34
Aug 08	0	0	0	1.08	1.45	0.20
Aug 15	0	0	0	0.96	1.34	0.26
Aug 22	0	0	0	1.12	1.42	0.29
Aug 29	0	0	0	1.02	1.41	0.30
Minimum				0.90	1.21	0.20
Maximum	0	0	0	1.12	1.45	0.34
Average				1.02	1.37	0.27
Count	6	6	6	5	5	6
Exceedences	0	0	0	0	0	

A minimum of 0.10 mg/L free chlorine residual **OR** 0.50 mg/L total chlorine residual is required in each bacteriological sample.

White City Distribution - Bacteriological							
August 2022	Sampling Location ()	Total Coliform (Count)	E. Coli (Count)	Background Bacteria (Count)	Free Chlorine (mg/L)	Total Chlorine (mg/L)	Turbidity (NTU)
Aug 02	Post Office	0	0	0	1.21	1.40	0.29
Aug 08	town offic	0	0	0	1.08	1.38	0.22
Aug 15	shop	0	0	0	0.96	1.27	0.28
Aug 22	post Offic	0	0	0	0.96	1.16	0.36
Aug 29	hydrant	0	0	0	1.02	1.21	1.62
Minimum					0.96	1.16	0.22
Maximum		0	0	0	1.21	1.40	1.62
Average					1.05	1.28	0.55
Count		5	5	5	5	5	5
Exceedences		0	0	0	0	0	

A minimum of 0.10 mg/L free chlorine residual **OR** 0.50 mg/L total chlorine residual is required in each bacteriological sample.

P.O. # SWC002308

(306) 787-7138 / (306) 787-3140

Environmental Services Analysis Report - Final

Invoice Number: 3415837	Collected Date: 29-Aug-2022 1:50 PM	
Sample Location: Jameson Sub. Div. Hydrant	Received: 29-Aug-2022 3:58 PM	
Collected by: N. Hodges	Reported: 30-Aug-2022 2:20 PM	
Station #: SK05JF0022 WHITE CITY DIST.SYSTEM	Water Source: Distributed	
Permit: 2574		

Submitted By:	Invoice:
SASK WATER	SASK WATER
225 A HELLEN DRIVE	225 A HELLEN DRIVE
RM OF SHERWOOD, SK	RM OF SHERWOOD, SK
S4K 0A3	S4K 0A3

Analysis	Result	Unit	Sask Guideline	Test Comment	Fee
Regular Panel					23.00
Total Coliform	No Detectable	orgs/100 mL	No orgs/100 mL	1	
E. Coli	No Detectable	orgs/100 mL	No orgs/100 mL	2	

Submitter Phone Number: 306-533-1936

Emailed results to: ReginaEastResults@saskwater.com

Comments:

1. Testing result indicates that your water meets the Bacteriological standard for Canadian drinking water quality.
2. See above for comment

Please include
Invoice Number
with payment
and remit to:

**Saskatchewan Health Authority
c/o Finance
2180 23rd Avenue
Regina, Saskatchewan
S4S 0A5**

Total Fees (including GST)	23.00
Tax Summary	1.10
G.S.T. (reg # 89583 0180 RT001)	
Amount Received: (No Payment Received)	0.00

Balance Due upon receipt of invoice.

Balance Owed	\$23.00
---------------------	----------------

Contact Us:

Result Interpretation: Please contact your EPO for advice or phone 306-535-4347

Billing Inquiries: Phone: (306) 766-5832, Fax: (306) 766-5188, Email: corpfinance@rqhealth.ca

The following data was provided by the submitter. The Environmental Services Lab does not guarantee the accuracy of the results.

Free Chlorine: 1.02	Total Chlorine: 1.21	Turbidity: 1.62
---------------------	----------------------	-----------------

SWC 2252

(306) 787-7138 / (306) 787-3140

Environmental Services Analysis Report - Final

Invoice Number: 3415213	Collected Date: 22-Aug-2022 1:05 PM
Sample Location: White City Post Office	Received: 22-Aug-2022 4:01 PM
Collected by: B52	Reported: 23-Aug-2022 2:24 PM
Station #: SK05JF0022	Water Source: Distributed

Permit: 2574
WHITE CITY DIST.SYSTEM

Submitted By: SASK WATER 225 A HELLEN DRIVE RM OF SHERWOOD, SK S4K 0A3	Invoice: SASK WATER 225 A HELLEN DRIVE RM OF SHERWOOD, SK S4K 0A3
---	--

Analysis	Result	Unit	Sask Guideline	Test Comment	Fee
Regular Panel					23.00
Total Coliform	No Detectable	orgs/100 mL	No orgs/100 mL	1	
E. Coli	No Detectable	orgs/100 mL	No orgs/100 mL	2	

Submitter Phone Number: 306-533-1936

Emailed results to: ReginaEastResults@saskwater.com

Comments:

1. Testing result indicates that your water meets the Bacteriological standard for Canadian drinking water quality.
2. See above for comment

Please include
Invoice Number
with payment
and remit to:

**Saskatchewan Health Authority
c/o Finance
2180 23rd Avenue
Regina, Saskatchewan
S4S 0A5**

Total Fees (including GST)	23.00
Tax Summary	1.10
G.S.T. (reg # 89583 0180 RT001)	
Amount Received: (No Payment Received)	0.00

Balance Due upon receipt of invoice.

Balance Owed	\$23.00
---------------------	----------------

Contact Us:

Result Interpretation: Please contact your EPO for advice or phone 306-535-4347

Billing Inquiries: Phone: (306) 766-5832, Fax: (306) 766-5188, Email: corpfinance@rqhealth.ca

The following data was provided by the submitter. The Environmental Services Lab does not guarantee the accuracy of the results.

Free Chlorine: .96	Total Chlorine: 1.16	Turbidity: .36
--------------------	----------------------	----------------

SWC 2223

(306) 787-7138 / (306) 787-3140

Environmental Services Analysis Report - Final

Invoice Number: 3414591	Collected Date: 15-Aug-2022 1:45 PM	
Sample Location: White City Town Shop	Received: 15-Aug-2022 4:04 PM	
Collected by: B. Stephenson	Reported: 16-Aug-2022 2:28 PM	
Station #: SK05JF0022	Water Source: Distributed	
Permit: 2574	WHITE CITY DIST.SYSTEM	

Submitted By:

SASK WATER
225 A HELLEN DRIVE
RM OF SHERWOOD, SK
S4K 0A3

Invoice:

SASK WATER
225 A HELLEN DRIVE
RM OF SHERWOOD, SK
S4K 0A3

Analysis	Result	Unit	Sask Guideline	Test Comment	Fee
Regular Panel					23.00
Total Coliform	No Detectable	orgs/100 mL	No orgs/100 mL	1	
E. Coli	No Detectable	orgs/100 mL	No orgs/100 mL	2	

Submitter Phone Number: 306-533-1936

Emailed results to: ReginaEastResults@saskwater.com

Comments:

1. Testing result indicates that your water meets the Bacteriological standard for Canadian drinking water quality.
2. See above for comment

Please include
Invoice Number
with payment
and remit to:

**Saskatchewan Health Authority
c/o Finance
2180 23rd Avenue
Regina, Saskatchewan
S4S 0A5**

Total Fees (including GST)	23.00
Tax Summary	1.10
G.S.T. (reg # 89583 0180 RT001)	
Amount Received: (No Payment Received)	0.00

Balance Due upon receipt of invoice.

Balance Owed	\$23.00
---------------------	----------------

Contact Us:

Result Interpretation: Please contact your EPO for advice or phone 306-535-4347

Billing Inquiries: Phone: (306) 766-5832, Fax: (306) 766-5188, Email: corpfinance@rqhealth.ca

The following data was provided by the submitter. The Environmental Services Lab does not guarantee the accuracy of the results.

Free Chlorine:	0.96	Total Chlorine:	1.27	Turbidity:	0.28
----------------	------	-----------------	------	------------	------

SWC002210

(306) 787-7138 / (306) 787-3140

Environmental Services Analysis Report - Final

Invoice Number: 3413956	Collected Date: 08-Aug-2022 8:30 AM	
Sample Location: White City Town Office	Received: 08-Aug-2022 1:57 PM	
Collected by: B. Stevenson	Reported: 09-Aug-2022 2:15 PM	
Station #: SK05JF0022 WHITE CITY DIST.SYSTEM	Water Source: Distributed	
Permit: 2574		

Submitted By: SASK WATER 225 A HELLEN DRIVE RM OF SHERWOOD, SK S4K 0A3	Invoice: SASK WATER 225 A HELLEN DRIVE RM OF SHERWOOD, SK S4K 0A3
---	--

Analysis	Result	Unit	Sask Guideline	Test Comment	Fee
Regular Panel					23.00
Total Coliform	No Detectable	orgs/100 mL	No orgs/100 mL	1	
E. Coli	No Detectable	orgs/100 mL	No orgs/100 mL	2	

Submitter Phone Number: 306-533-1936

Emailed results to: ReginaEastResults@saskwater.com

Comments:

1. Testing result indicates that your water meets the Bacteriological standard for Canadian drinking water quality.
2. See above for comment

Please include
Invoice Number
with payment
and remit to:

**Saskatchewan Health Authority
c/o Finance
2180 23rd Avenue
Regina, Saskatchewan
S4S 0A5**

Total Fees (including GST)	23.00
Tax Summary	1.10
G.S.T. (reg # 89583 0180 RT001)	
Amount Received: (No Payment Received)	0.00

Balance Due upon receipt of invoice.

Balance Owed	\$23.00
---------------------	----------------

Contact Us:

Result Interpretation: Please contact your EPO for advice or phone 306-535-4347

Billing Inquiries: Phone: (306) 766-5832, Fax: (306) 766-5188, Email: corpfinance@rqhealth.ca

The following data was provided by the submitter. The Environmental Services Lab does not guarantee the accuracy of the results.

Free Chlorine:	1.08	Total Chlorine:	1.38	Turbidity:	.22
----------------	------	-----------------	------	------------	-----

SWC002177

(306) 787-7138 / (306) 787-3140

Environmental Services Analysis Report - Final

Invoice Number:	3413472	Collected Date:	02-Aug-2022 11:50 AM
Sample Location:	White City Post Office	Received:	02-Aug-2022 1:39 PM
Collected by:	B. Stevenson	Reported:	03-Aug-2022 2:55 PM
Station #:	SK05JF0022	Water Source:	Distributed
	WHITE CITY DIST.SYSTEM		

Submitted By: SASK WATER 225 A HELLEN DRIVE RM OF SHERWOOD, SK S4K 0A3	Invoice: SASK WATER 225 A HELLEN DRIVE RM OF SHERWOOD, SK S4K 0A3
---	--

Analysis	Result	Unit	Sask Guideline	Test Comment	Fee
Regular Panel					23.00
Total Coliform	No Detectable	orgs/100 mL	No orgs/100 mL	1	
E. Coli	No Detectable	orgs/100 mL	No orgs/100 mL	2	

Submitter Phone Number: 306-533-1936

Emailed results to: ReginaEastResults@saskwater.com

Comments:

1. Testing result indicates that your water meets the Bacteriological standard for Canadian drinking water quality.
2. See above for comment

Please include
Invoice Number
with payment
and remit to:
**Saskatchewan Health Authority
c/o Finance
2180 23rd Avenue
Regina, Saskatchewan
S4S 0A5**

Total Fees (including GST)	23.00
Tax Summary	1.10
G.S.T. (reg # 89583 0180 RT001)	
Amount Received: (No Payment Received)	0.00

Balance Due upon receipt of invoice.

Balance Owed	\$23.00
---------------------	----------------

Contact Us:

Result Interpretation:	Please contact your EPO for advice or phone 306-535-4347
Billing Inquiries:	Phone: (306) 766-5832, Fax: (306) 766-5188, Email: corpfinance@rqhealth.ca

The following data was provided by the submitter. The Environmental Services Lab does not guarantee the accuracy of the results.

Free Chlorine:	1.21	Total Chlorine:	1.40	Turbidity:	.29
----------------	------	-----------------	------	------------	-----