

| White City WTP | | | | | | | | | | |
|--------------------|---------------------------|-------------------------------|---|--|---|---|--------------------------------------|--|-------------------------------|------------------------------------|
| April 2023 | Raw Volume (m3) Avg | Treated Volume (m3) Avg | Treated Free Chlorine (mg/L) Min | Treated Total Chlorine (mg/L) Min | Treated Free Chlorine (Analyser) (mg/L) Min | Treated pH (Analyser) (pH units) Avg | Treated Turbidity (NTU) Max | Treated Turbidity (Analyser) (NTU) Max | Treated Iron (mg/L) Avg | Treated Manganese (mg/L) Avg |
| Apr 01 | 847 | 1114 | 0.95 | 1.34 | 1.00 | 7.13 | 0.15 | 0.024 | | 0.016 |
| 02 | 579 | 608 | 1.03 | 1.39 | 1.00 | 7.13 | 0.17 | 0.027 | | 0.014 |
| 03 | 784 | 726 | 0.95 | 1.26 | 1.00 | 7.13 | 0.07 | 0.025 | 0.00 | 0.020 |
| 04 | 580 | 558 | 0.89 | 1.29 | 0.99 | 7.13 | 0.08 | 0.025 | | 0.029 |
| 05 | 741 | 593 | 1.03 | 1.36 | 0.97 | 7.11 | 0.09 | 0.025 | | 0.013 |
| 06 | 606 | 617 | 0.99 | 1.29 | 0.95 | 7.11 | 0.10 | 0.025 | | 0.015 |
| 07 | 582 | 608 | 0.96 | 1.31 | 0.92 | 7.11 | 0.11 | 0.035 | | 0.027 |
| 08 | 780 | 711 | 0.76 | 1.21 | 0.92 | 7.13 | 0.12 | 0.025 | | 0.010 |
| 09 | 392 | 398 | 0.90 | 1.27 | 0.88 | 7.11 | 0.12 | 0.024 | | 0.017 |
| 10 | 850 | 664 | 0.90 | 1.25 | 0.88 | 7.11 | 0.11 | 0.024 | 0.01 | 0.013 |
| 11 | 758 | 757 | 0.92 | 1.16 | 0.87 | 7.11 | 0.18 | 0.026 | | 0.071 |
| 12 | 532 | 581 | 0.86 | 1.23 | 0.86 | 7.11 | 0.10 | 0.024 | | 0.021 |
| 13 | 748 | 635 | 0.82 | 1.18 | 0.88 | 7.11 | 0.09 | 0.025 | | 0.011 |
| 14 | 716 | 601 | 0.89 | 1.21 | 0.87 | 7.11 | 0.08 | 0.024 | | 0.022 |
| 15 | 552 | 580 | 0.88 | 1.23 | 0.89 | 7.13 | 0.07 | 0.025 | | 0.012 |
| 16 | 654 | 646 | 0.87 | 1.17 | 0.86 | 7.11 | 0.09 | 0.025 | | 0.024 |
| 17 | 785 | 727 | 0.88 | 1.22 | 0.87 | 7.11 | 0.11 | 0.024 | 0.01 | 0.012 |
| 18 | 747 | 637 | 0.80 | 1.21 | 0.86 | 7.11 | 0.07 | 0.023 | | 0.012 |
| 19 | 756 | 693 | 0.85 | 1.22 | 0.85 | 7.11 | 0.09 | 0.027 | | 0.014 |
| 20 | 489 | 543 | 0.82 | 1.25 | 0.84 | 7.11 | 0.13 | 0.025 | | 0.014 |
| 21 | 639 | 598 | 0.85 | 1.21 | 0.82 | 7.11 | 0.11 | 0.025 | | 0.017 |
| 22 | 600 | 613 | 0.85 | 1.21 | 0.85 | 7.11 | 0.11 | 0.022 | | 0.026 |
| 23 | 785 | 653 | 0.89 | 1.21 | 0.85 | 7.13 | 0.07 | 0.023 | | 0.017 |
| 24 | 671 | 657 | 0.86 | 1.28 | 0.88 | 7.11 | 0.09 | 0.024 | 0.01 | 0.025 |
| 25 | 686 | 646 | 0.87 | 1.16 | 0.90 | 7.11 | 0.09 | 0.023 | 0.00 | 0.011 |
| 26 | 603 | 582 | 0.85 | 1.25 | 0.90 | 7.11 | 0.11 | 0.023 | | 0.012 |
| 27 | 495 | 519 | 0.85 | 1.25 | 0.90 | 7.11 | 0.07 | 0.023 | | 0.011 |
| 28 | 998 | 722 | 0.95 | 13.32 | 0.92 | 7.13 | 0.07 | 0.026 | | 0.003 |
| 29 | 420 | 639 | 0.98 | 1.32 | 0.95 | 7.13 | 0.09 | 0.026 | | 0.021 |
| 30 | 793 | 616 | 0.98 | 1.19 | 0.95 | 7.13 | 0.08 | 0.032 | | 0.018 |
| Minimum | 392 | 398 | 0.76 | 1.16 | 0.82 | 7.11 | 0.07 | 0.022 | 0.00 | 0.003 |
| Maximum | 998 | 1114 | 1.03 | 13.32 | 1.00 | 7.13 | 0.18 | 0.035 | 0.01 | 0.071 |
| Average | 672 | 641 | 0.90 | 1.65 | 0.90 | 7.12 | 0.10 | 0.025 | 0.01 | 0.018 |
| Count | | | 30 | 30 | 30 | 30 | 30 | 30 | 5 | 30 |
| Total | 20168 | 19242 | | | | | | | | |
| 95th Percentile | | | | | | | 0.15 | 0.027 | | |
| Exceedences | | | 0 | | 0 | | | | | |

If there is more than one per day reading for free chlorine residual, the daily minimum is reported.

If there is more than one per day reading for turbidity, the daily maximum is reported.

| White City WTP - Bacteriological (Raw Water) | | | |
|--|---------------------------|--------------------|-----------------------------------|
| April 2023 | Total Coliform (Count) | E. Coli (Count) | Background Bacteria (Count) |
| Apr 01 | | | |

| White City WTP - Bacteriological | | | | | | |
|----------------------------------|------------------------|-----------------|-----------------------------|----------------------|-----------------------|-----------------|
| April 2023 | Total Coliform (Count) | E. Coli (Count) | Background Bacteria (Count) | Free Chlorine (mg/L) | Total Chlorine (mg/L) | Turbidity (NTU) |
| Apr 03 | 0 | 0 | 0 | 0.95 | 1.26 | 0.07 |
| Apr 10 | 0 | 0 | 0 | 0.90 | 1.25 | 0.11 |
| Apr 17 | 0 | 0 | 0 | 0.88 | 1.22 | 0.11 |
| Apr 24 | 0 | 0 | 0 | 0.86 | 1.28 | 0.09 |
| Minimum | | | | 0.86 | 1.22 | 0.07 |
| Maximum | 0 | 0 | 0 | 0.95 | 1.28 | 0.11 |
| Average | | | | 0.90 | 1.25 | 0.10 |
| Count | 4 | 4 | 4 | 4 | 4 | 4 |
| Exceedences | 0 | 0 | 0 | 0 | 0 | |

A minimum of 0.10 mg/L free chlorine residual **OR** 0.50 mg/L total chlorine residual is required in each bacteriological sample.

| White City Distribution - Bacteriological | | | | | | | |
|---|-----------------------|------------------------|-----------------|-----------------------------|----------------------|-----------------------|-----------------|
| April 2023 | Sampling Location () | Total Coliform (Count) | E. Coli (Count) | Background Bacteria (Count) | Free Chlorine (mg/L) | Total Chlorine (mg/L) | Turbidity (NTU) |
| Apr 03 | TownShop | 0 | 0 | 0 | 0.98 | 1.36 | 0.10 |
| Apr 10 | 6 Capital Place | 0 | 0 | 0 | 0.83 | 1.15 | 0.16 |
| Apr 17 | oldschool | 0 | 0 | 0 | 0.82 | 1.12 | 0.11 |
| Apr 24 | Postoffice | 0 | 0 | 0 | 0.84 | 1.39 | 0.09 |
| Minimum | | | | | 0.82 | 1.12 | 0.09 |
| Maximum | | 0 | 0 | 0 | 0.98 | 1.39 | 0.16 |
| Average | | | | | 0.87 | 1.26 | 0.12 |
| Count | | 4 | 4 | 4 | 4 | 4 | 4 |
| Exceedences | | 0 | 0 | 0 | 0 | 0 | |

A minimum of 0.10 mg/L free chlorine residual **OR** 0.50 mg/L total chlorine residual is required in each bacteriological sample.

Environmental Services Analysis Report - Final

| | |
|--|--|
| Invoice Number: 3430792 | Collected Date: 03-Apr-2023 1:00 PM |
| Sample Location: White City Town Shop | Received: 03-Apr-2023 2:32 PM |
| Collected by: E. Megenbir | Reported: 04-Apr-2023 2:13 PM |
| Station #: SK05JF0022 | Water Source: Distributed |
| Permit: 2574 | |
| WHITE CITY DIST.SYSTEM | |

Submitted By:

SASK WATER
225 A HELLEN DRIVE
RM OF SHERWOOD, SK
S4K 0A3

Invoice:

SASK WATER
225 A HELLEN DRIVE
RM OF SHERWOOD, SK
S4K 0A3

| Analysis | Result | Unit | Sask Guideline | Test Comment | Fee |
|----------------|---------------|-------------|----------------|--------------|-------|
| Regular Panel | | | | | 23.00 |
| Total Coliform | No Detectable | orgs/100 mL | No orgs/100 mL | 1 | |
| E. Coli | No Detectable | orgs/100 mL | No orgs/100 mL | 2 | |

Submitter Phone Number: 306-533-1936

Emailed results to: ReginaEastResults@saskwater.com

Comments:

1. Testing result indicates that your water meets the Bacteriological standard for Canadian drinking water quality.
2. See above for comment

Please include
Invoice Number
with payment
and remit to:

Saskatchewan Health Authority
c/o Finance
2180 23rd Avenue
Regina, Saskatchewan
S4S 0A5

Total Fees (including GST) 23.00

Tax Summary 1.10
G.S.T. (reg # 89583 0180 RT001)

Amount Received: (No Payment Received) 0.00

Balance Due upon receipt of invoice.

| | |
|---------------------|----------------|
| Balance Owed | \$23.00 |
|---------------------|----------------|

Contact Us:

Result Interpretation: Please contact your EPO for advice or phone 306-535-4347
Billing Inquiries: Phone: 1-833-989-5353, Email: shaar@saskhealthauthority.ca

The following data was provided by the submitter. The Environmental Services Lab does not guarantee the accuracy of the results.

| | | | | | |
|----------------|------|-----------------|------|------------|------|
| Free Chlorine: | 0.98 | Total Chlorine: | 1.36 | Turbidity: | 0.10 |
|----------------|------|-----------------|------|------------|------|

Environmental Services Analysis Report - Final

| | |
|--|--|
| Invoice Number: 3430792 | Collected Date: 03-Apr-2023 1:00 PM |
| Sample Location: White City Town Shop | Received: 03-Apr-2023 2:32 PM |
| Collected by: E. Megenbir | Reported: 04-Apr-2023 2:13 PM |
| Station #: SK05JF0022 | Water Source: Distributed |
| Permit: 2574 | |
| WHITE CITY DIST.SYSTEM | |

Submitted By:

SASK WATER
225 A HELLEN DRIVE
RM OF SHERWOOD, SK
S4K 0A3

Invoice:

SASK WATER
225 A HELLEN DRIVE
RM OF SHERWOOD, SK
S4K 0A3

| Analysis | Result | Unit | Sask Guideline | Test Comment | Fee |
|----------------|---------------|-------------|----------------|--------------|-------|
| Regular Panel | | | | | 23.00 |
| Total Coliform | No Detectable | orgs/100 mL | No orgs/100 mL | 1 | |
| E. Coli | No Detectable | orgs/100 mL | No orgs/100 mL | 2 | |

Submitter Phone Number: 306-533-1936

Emailed results to: ReginaEastResults@saskwater.com

Comments:

1. Testing result indicates that your water meets the Bacteriological standard for Canadian drinking water quality.
2. See above for comment

Please include
Invoice Number
with payment
and remit to:

Saskatchewan Health Authority
c/o Finance
2180 23rd Avenue
Regina, Saskatchewan
S4S 0A5

Total Fees (including GST) 23.00

Tax Summary 1.10
G.S.T. (reg # 89583 0180 RT001)

Amount Received: (No Payment Received) 0.00

Balance Due upon receipt of invoice.

| | |
|---------------------|----------------|
| Balance Owed | \$23.00 |
|---------------------|----------------|

Contact Us:

Result Interpretation: Please contact your EPO for advice or phone 306-535-4347
Billing Inquiries: Phone: 1-833-989-5353, Email: shaar@saskhealthauthority.ca

The following data was provided by the submitter. The Environmental Services Lab does not guarantee the accuracy of the results.

| | | | | | |
|----------------|------|-----------------|------|------------|------|
| Free Chlorine: | 0.98 | Total Chlorine: | 1.36 | Turbidity: | 0.10 |
|----------------|------|-----------------|------|------------|------|

Environmental Services Analysis Report - Final

| | |
|---|---|
| Invoice Number: 3431750 | Collected Date: 17-Apr-2023 10:50 AM |
| Sample Location: White City School (Old) | Received: 17-Apr-2023 2:04 PM |
| Collected by: W. Matts | Reported: 18-Apr-2023 2:39 PM |
| Station #: SK05JF0022 | Water Source: Distributed |
| Permit: 2574 | |
| WHITE CITY DIST.SYSTEM | |

Submitted By:

SASK WATER
225 A HELLEN DRIVE
RM OF SHERWOOD, SK
S4K 0A3

Invoice:

SASK WATER
225 A HELLEN DRIVE
RM OF SHERWOOD, SK
S4K 0A3

| Analysis | Result | Unit | Sask Guideline | Test Comment | Fee |
|----------------|---------------|-------------|----------------|--------------|-------|
| Regular Panel | | | | | 23.00 |
| Total Coliform | No Detectable | orgs/100 mL | No orgs/100 mL | 1 | |
| E. Coli | No Detectable | orgs/100 mL | No orgs/100 mL | 2 | |

Submitter Phone Number: 306-533-1936

Emailed results to: ReginaEastResults@saskwater.com

Comments:

1. Testing result indicates that your water meets the Bacteriological standard for Canadian drinking water quality.
2. See above for comment

Please include
Invoice Number
with payment
and remit to:

Saskatchewan Health Authority
c/o Finance
2180 23rd Avenue
Regina, Saskatchewan
S4S 0A5

Total Fees (including GST) 23.00

Tax Summary 1.10
G.S.T. (reg # 89583 0180 RT001)

Amount Received: (No Payment Received) 0.00

Balance Due upon receipt of invoice.

| | |
|---------------------|----------------|
| Balance Owed | \$23.00 |
|---------------------|----------------|

Contact Us:

Result Interpretation: Please contact your EPO for advice or phone 306-535-4347
Billing Inquiries: Phone: 1-833-989-5353, Email: shaar@saskhealthauthority.ca

The following data was provided by the submitter. The Environmental Services Lab does not guarantee the accuracy of the results.

| | | | | | |
|----------------|------|-----------------|------|------------|------|
| Free Chlorine: | 0.82 | Total Chlorine: | 1.12 | Turbidity: | 0.11 |
|----------------|------|-----------------|------|------------|------|

Environmental Services Analysis Report - Final

| | | |
|-------------------------------------|---|---|
| Invoice Number: 3432181 | Collected Date: 24-Apr-2023 10:20 AM | |
| Sample Location: Post Office | Received: 24-Apr-2023 2:13 PM | |
| Collected by: B. Stevenson | Reported: 25-Apr-2023 2:08 PM | |
| Station #: SK05JF0022 | Water Source: Distributed | Permit: 2574 WHITE CITY DIST.SYSTEM |

Submitted By:

SASK WATER
225 A HELLEN DRIVE
RM OF SHERWOOD, SK
S4K 0A3

Invoice:

SASK WATER
225 A HELLEN DRIVE
RM OF SHERWOOD, SK
S4K 0A3

| Analysis | Result | Unit | Sask Guideline | Test Comment | Fee |
|----------------|---------------|-------------|----------------|-----------------|-------|
| Regular Panel | | | | | 23.00 |
| Total Coliform | No Detectable | orgs/100 mL | No orgs/100 mL | 1 | |
| E. Coli | No Detectable | orgs/100 mL | No orgs/100 mL | 2 | |

Submitter Phone Number: 306-533-1936

Emailed results to: ReginaEastResults@saskwater.com

Comments:

1. Testing result indicates that your water meets the Bacteriological standard for Canadian drinking water quality.
2. See above for comment

Please include
Invoice Number
with payment
and remit to:

**Saskatchewan Health Authority
c/o Finance
2180 23rd Avenue
Regina, Saskatchewan
S4S 0A5**

Total Fees (including GST) 23.00

Tax Summary 1.10
G.S.T. (reg # 89583 0180 RT001)

Amount Received: (No Payment Received) 0.00

Balance Due upon receipt of invoice.

| | |
|---------------------|----------------|
| Balance Owed | \$23.00 |
|---------------------|----------------|

Contact Us:

Result Interpretation: Please contact your EPO for advice or phone 306-535-4347
Billing Inquiries: Phone: 1-833-989-5353, Email: shaar@saskhealthauthority.ca

The following data was provided by the submitter. The Environmental Services Lab does not guarantee the accuracy of the results.

| | | |
|--------------------|----------------------|----------------|
| Free Chlorine: .84 | Total Chlorine: 1.39 | Turbidity: .09 |
|--------------------|----------------------|----------------|